

Auto Transfer

Issue 2

Switch control

DESCRIPTION

The 705 is an Automatic Transfer Switch controller which will monitor the incoming AC mains (utility) supply. Should a Mains (utility) failure occur the 705 will instruct the genset to start and take load. It utilises advanced surface mount construction techniques to provide a compact yet highly specified module.

Operation of the module is via three pushbuttons mounted on the front panel with Manual off load, Manual on load and Auto positions. Selection of the Auto mode is confirmed by LED indicator, and monitors the incoming mains (utility) supply (3 phase or single phase). Should the incoming AC mains (utility) supply fall below a configurable pre-set limit (180V default), the generator will be requested to start, and load transferred to the genset.

When the AC mains (utility) supply returns within limits, the module will wait for a configurable, stabilisation period, and then transfer load back to the mains. The engine will be requested to stop after a cool-down period.

The module's microprocessor provides a comprehensive list of timers and functions, and access to the settings is via a small Configuration Switch on the rear of the module. Parameter settings can be adjusted using the front panel pushbuttons once in Configuration Mode.

The module monitors the engine and provides the following functions:

- \triangleright Mains (utility) failure detection with configurable fail and return timers.
- \triangleright Adjustable Warming and cooling timers.
- Adjustable Mains (utility) Fail voltage > level.
- Changeover contactor control with ≻ LED mimic.
- ≻ Generator available indication (from genset frequency).
- \triangleright Engine Start signal.

Issues such as environmental compliance and EMC have been carefully engineered into the design. Advanced features such as Protected Solid State Outputs mean that there are no moving parts or contacts to burn out.

OPERATION

Manual off load for mode - This is used to manually start and run the engine off load. Should the mains (utility) supply fail, then the load is transferred to the generator automatically.

Manual on load for mode - This is used to manually start and run the engine on load.

AUTO mode - This selects the automatic mode of operation, in which the module will await a mains failure. Once detected, the module will initiate its pre-configured start sequence, observing the Start Delay Timer before starting the engine. When the mains supply returns, the module will initiate its pre-configured stopping sequence.

FEATURES

- Micro-processor based design
- ≻ Automatic Mains failure detection
- Control of the Contactors or change-over device
- > Configurable via front panel
- Simple pushbutton controlled operation
- **Configurable Timer Settings** ≻
- ≻ **Solid State Start Outputs**
- **External Remote Start Input** >
- ≻ **LED Mimic indication**
- ≻ Mains Fail/ Return Delay Timer
- ≻ Warm-up/Cooling Timer

Neutral position")

- Single/Three phase mains sensing > Load contactor control Solid State >
- Outputs Load shedding input ("Close to ≻



SPECIFICATION

DC Supply:

8 to 35 V Continuous. **Cranking Dropouts:** Able to survive 0V for 50ms. providing supply was at least 10V before dropout and supply recovers to 5V. This is achieved without the need for internal batteries.

Max. Current:

Operating 50mA Standby 10mA

Alternator Input Range: 75(ph-N) to 277(ph-N) 3 Phase 4 wire AC (+20%)

Alternator Input Frequency: 50 - 60 Hz at rated engine speed (Minimum: 75V AC Ph-N) Genset available from 45Hz

Start Request Output:

1.2 Amp DC at supply voltage.

Auxiliary Outputs:

1.2 Amp DC at supply voltage. **Dimensions:**

165mm x 125mm x 29mm (6.5" x 4.9" x 1.2") **Operating Temperature Range:**

 -30° to $+70^{\circ}$ C

- ≻ Compliant with BS EN 60950 Low Voltage Directive
- Compliant with BS EN 50081-2 **EMC** Directive
- Compliant with BS EN 50082-2 EMC Directive

The 700 series modules have been designed for front panel mounting. The module is fitted into the cut-out, and screw holes are provided for secure fixing.

CONFIGURATION

Configuration Mode is selected by operation of a small switch on the rear, left-hand edge of the PCB. This is partially hidden to prevent accidental operation. See figs 1 and 2



Deep Sea Electronics Pic.Deep Sea Electronics Inc.Highfield House, Hunmanby Industrial Estate,
North Yorkshire. YO14 0PH. ENGLAND
Tel +44 (0)1723 890099.5301 E. State St. – Suite 202
Rockford, Illinois 61108. U.S.A.
Phone +1 (815) 316-8706
Fax +14 (0)1723 893303.Fax +44 (0)1723 893303.Fax +1 (815) 316-8708
Fax +1 (815) 316-8708Email - sales@deepseaplc.com
Web - www.deepseaplc.comEmail - dsesales@deepseausa.com
Web - www.deepseausa.com